



Chicora, PLLC

*"Success is Sincere Effort and Skillful Execution"*

CONSTRUCTION MANAGEMENT • CIVIL DESIGN • CONSULTING

NC Registered Engineering Firm P-1697

**January 13, 2020**

Dennis Hunt  
Exterior R US  
1201 West Church St.  
Laurinburg, NC 28352


Re: Foundation Observation  
7268 Elliot Bridge Rd  
Spring Lake, NC 28390  
Project No. 202-04320

To Whom It May Concern:

Chicora, PLLC was requested to observe the foundation footings for the proposed deck for the existing structure. The footings observed will approximately be 4 ft. on center. The foundation footings were excavated approximately 14 to 16 inches in diameter and 12 inches in depth. The soil layers that were observed in the hole were a brown sandy clayey material. Chicora, PLLC did not observe any water or debris in the holes that were excavated.

It's in the opinion of the Chicora, PLLC that proposed foundation and soils in place will be structurally suitable to support the proposed structure.

We appreciate the opportunity to help you with this. Should you have any questions or need additional information, please contact us at your earliest convenience. We can be reached at [dlowery.chicora@gmail.com](mailto:dlowery.chicora@gmail.com).



Dennis Lowery, PE  
License No. 043840