


Ceiling rafters 2x6 to span no more than 4' in upper 3rd of ceiling 16" OC



APPROVED
 Limited building only review
 Permit holder responsible for
 full compliance with the code

NOTICE TO CONTRACTOR
 All construction must comply with current NC Building Codes
 and is subject to field inspection and verification.

Deck is existing Double 2x10 Band all 3 sides
 2x10 FT 160c on large section 2x8 FT 16" OC on small section
 Deck supports are CAG Post at same locations as 4x4 Post shown on Plans

Existing Deck / Stairs

Build new porch on existing deck

Existing Deck has Double 2x10 Band on all 3 sides

