

Date: 6.23.20

To: Harnet County Inspections From: John McGahey, AIA, NCARB

Re: Charles Perry: 41 Benton Farm Way, Fuguay-Varina, NC 27526

Inspections Department,

I have reviewed the onsite framing modifications.

Removing the exterior and adding (2) 9 1/4" LVL's (max span of 13'-0") will support the roof bearing and ceiling joists.

If you have any questions or comments, please email or call me at: email: john@mcgaheydesign.com or 919.422.0265.

Sincerely,

John M. McGahey, AIA, NCARB

cc: Danny Vuncannon

6.23.20