Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

Sheet: Property ID: Lot #: File#: Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Site LTAR

Owner: Applicant: Tim OHY Settle Address: Proposed Facility: DWMH30'x5' Design Flow (.1949): 360G PD Property Size: Location of Site: 8500HCA Property Recorded: Water Supply: Public Individual Well Spring Other Evaluation Method: Auger Boring Pit Cut Type of Wastewater: Sewage Industrial Process Mixed												
P R O F I L E	.1940 Landscape Position/ Slope %	Horizon Depth (ln.)		DRPHOLOGY .1941 .1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	OTHER PROFILE FACTOR .1943 Soil Depth (IN.)	S .1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR			
1,2,3	L 65°	0-48	GR SL	VFR SEXP	nsnp	48"			5.6			
-												
Description Initial Repair System Other Factors (.1946): System Site Classification (.1948): Surfable 1 1120												
Available Space (.1945) System Type(s)			Site Classification (.1948): Surfable Evaluated By: Others Present:									

Others Present:

COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	<u>TEXTURES</u>	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET	
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY	
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	III	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC	
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN		SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3			
	IV	SIC-SILTY CLAY	0.4 - 0.1			

STRUCTURE SG-SINGLE GRAIN M- MASSIVE CR-CRUMB **GR-GRANULAR** SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY

MINERALOGY SLIGHTLY EXPANSIVE

SIC-SILTY CLAY C-CLAY SC-SANDY CLAY

EXPANSIVE

PL-PLATY PR-PRISMATIC Show profile locations and other site features (dimensions, references or benchmark, and North) 1

Suff Rd