



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

6/15/2020

SUBJECT: BRES2002-0042
BUILDING RESIDENTIAL

To: Kodiak Industries Inc.

Here are the results of all Inspections located at **64 WYOMING CT:**

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 3/16/2020
Completed Date/Time: 3/16/2020
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: lock box front door code:3501

Need contractor or super on site to go over work being done. Contact me at 910-984-4772 to schedule time



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 3/18/2020
Completed Date/Time: 3/19/2020
Inspector: Slade Burton Lawson III
Result: CANCELLED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 4/7/2020
Completed Date/Time: 4/7/2020
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: Need engineer letter that states size of LVL installed is sufficient, 3 full length studs on each end for full bearing of LVL, Letter also needs to state that notching of LVL at both ends does not adversely effect integrity of LVL. Strap four stud columns, Fire caulk/foam missing throughout on Mechanical/Electrical, Do NOT insulate

Inspection Type: ROUGH IN
Scheduled Date/Time: 4/24/2020
Completed Date/Time: 4/24/2020
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: INSULATION
Scheduled Date/Time: 4/28/2020
Completed Date/Time: 4/28/2020
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 5/28/2020
Completed Date/Time: 5/28/2020
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: code is 3501
Drain line on d/w not installed per code, seal around water closets,



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: TAX INSPECTION
Scheduled Date/Time: 6/12/2020
Completed Date/Time:
Inspector: Terry Wade
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 6/12/2020
Completed Date/Time: 6/12/2020
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: