

March 12, 2020

ph: 910-893-7547

fax: 910-893-9371

Ronald Williams
69 Trophy Ridge
Fuquay-Varina, NC 27526

RE: Existing Tank Application # BRES2002-0049

Mr Ronald Williams:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

4. **Other – Proposed pool encroaches on 15ft minimum septic system setback. Existing system flagged onsite and homeowner provided options on approvable pool location, size and shape. Homeowner instructed to revise paperwork and reflag pool accordingly for approval.**

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting