

HTE #: BRES2003-0022

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Sheila Minshcew Phone #: (910)610-8443

Address: 424 Live Oak Road Coats, NC 27521

Name of Mobile Home Park or S/D: NA

Name of Owner (if different): Jeffery & Sheila Minshcew

Address of Owner (if different): 424 Live Oak Road Coats, NC 27521

Property Location (State Road name and #): 424 Live Oak Rd. (SR 1553)

Purpose of Inspection: 45'x31' addit. to include: entry rm, den, bonus room

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

03/19/2020
Date