



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

9/25/2020

SUBJECT: BRES2003-0023
BUILDING RESIDENTIAL

To: Creative Stone

Here are the results of all Inspections located at **35 RED BUD CIR:**

Inspection Type: INSULATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 6/5/2020
Completed Date/Time: 6/7/2020
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: See approved plan in attachments
Cus will call to discuss LR
Move access opening out of shower, shower pan test down, head test down, seal around plumbing openings in garage, insulate p-trap garage, all inspections need to be called in at same time

Inspection Type: ROUGH IN
Scheduled Date/Time: 6/15/2020
Completed Date/Time: 6/15/2020
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:





Harnett County
108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 9/16/2020
Completed Date/Time: 9/16/2020
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes: