



Peak Truss Builders, LLC

PO Box 340, New Hill, NC 27562

Comments and Clarifications

Job #:	Description:	Notes:
Q-2000853	Jose Santiago	Roof Trusses 2' OC, 2' Cantilever, 3' Overhang
Customer:	Contact:	
Chuck Smith Construction		
Address:	Site Address:	
129 Steel St Sanford NC 27330		
O: (919) 776.9097 Chuck Smith (919) 708.3351		

Truss Design Date:

- 1.All exterior/bearing walls are 2x4 (3-1/2" wide) unless otherwise noted.
- 2.All perimeter dimensions on layout reflect outside to outside of the sheathing. Studs are held in 1/2" to allow sheathing to line up with edge of slab.
- 3.Cantilever-- 2'; Overhang - - horizontal truss dimension is 3'. Sub-fascia and fascia are beyond.
- 4.All trusses and engineered wood require proper bracing and blocking. Some bracing guidance is provided in our Field Installation Package. However, "systematic" or "whole house" bracing is the responsibility of the Engineer of Record.

I have Reviewed and Approved above Clarifications:

Signed: _____

Date: _____