

# CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT


Name: (owner) Tristar Investment Corp / Boyd Basley  New Installation  Septic Tank  
Property Location: SR# 1769 → 2090  Repairs  Nitrification Line  
Subdivision Kennedy Acres Lot # ~~13~~ 13 BL  
TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Contractor: L. P. Contractors Registration # 13

Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface Drainage Field: No. of ditches 4 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 24 in.  
French Drain: \_\_\_\_\_ Linear feet

PERMIT NO. 8048 Date: 5-12-94  
Inspected by: Thomas G. Boyce  
Environmental Health Specialist



# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Tristar Investment Corp/ Boyd Brasley  New Installation  Septic Tank  
Property Location: SR# 2090  Repairs  Nitrification Line

Subdivision Kennedy Acres Lot # B

Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: .57 ac

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 100 + ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 24 in.

French Drain required: \_\_\_\_\_ Linear feet


This permit is subject to revocation if site plans or intended use change.

Date: 11-17-93

Signed: Thomas J. Boyd

Environmental Health Specialist

VOID AFTER 5 YEARS



Maintain Setbacks  
5' from house  
10' from property lines  
15' from ditch