

MARSHALL ENGINEERING SERVICES, PLLC

7575 McArtans Ford

Linden, NC 28356

(910) 850 5874

Corp. License P-0682

Randolph@RandolphMarshall.com

Gregory Gay

Construction Solutions

211 Clairmont St

Fayetteville, NC

1 July 2020

Subject: 168 Cresthaven Revision

The construction drawings stamped 29 April 2020 show double 2x10 rim joists and double 2x10 girders. The 2x10 material allowed for 2x2 ledgers to support the 2x8 floor joists. Double 2x8 rim joists and double 2x8 girders will be adequate if the joists are attached with metal hangers.

Please call my office if you have any questions or need additional engineering support.

Sincerely,


E. Randolph Marshall, PE



1 July 2020