



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

11/13/2024

SUBJECT: BRES2004-0011
BUILDING RESIDENTIAL

To: Gregory Spencer Gay

Here are the results of all Inspections located at **165 CRESTHAVEN DR:**

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: TAX INSPECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Tax Inspection
Result:
Remarks:
Notes:





Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOOTING
Scheduled Date/Time: 5/27/2020
Completed Date/Time: 5/27/2020
Inspector: Scott Guy
Result: APPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to TSG

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 7/1/2020
Completed Date/Time: 7/1/2020
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG
Must schedule Foundation inspection. Remove soils from piers and foundation to verify projection. Engineered plans call for double 2x10 girder, double 2x8 girder installed, either replace with proper size or provide engineering letter.

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 7/2/2020
Completed Date/Time: 7/2/2020
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG

Inspection Type: FOUNDATION
Scheduled Date/Time: 7/2/2020
Completed Date/Time: 7/2/2020
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG

Inspection Type: ROUGH IN
Scheduled Date/Time: 8/3/2020
Completed Date/Time: 8/3/2020
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG
Inspector SPG changed the inspection assignment from SPG to SBL





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: All windows within 24" of door openings must be tempered, provide instructions on install of flashing tape around windows, install door or cover with OSB, unable to locate waste water
Scheduled Date/Time: test, missing roof boot, do not insulate.
Completed Date/Time:

Inspector:

Inspection Type: ROUGH IN
Scheduled Date/Time: 8/5/2020
Completed Date/Time: 8/5/2020
Inspector: Slade Burton Lawson III
Result: APPROVED W/EXC

Remarks:

Notes: Tempered windows by doors need to be tempered

Inspection Type: INSULATION
Scheduled Date/Time: 8/12/2020
Completed Date/Time: 8/13/2020
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: INSULATION
Scheduled Date/Time: 8/13/2020
Completed Date/Time: 8/13/2020
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 9/16/2020
Completed Date/Time: 9/16/2020
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: this is for deck

Inspector SBL changed the inspection assignment from SBL to SPG

Inspection Type: FOOTING
Scheduled Date/Time: 9/16/2020
Completed Date/Time: 9/16/2020
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: Footing for deck see Eng Letter





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: Inspector SBL changed the inspection assignment from SBL to SPG
Scheduled Date/Time:

Inspection Type: FINAL**
Scheduled Date/Time: 11/3/2020
Completed Date/Time: 11/3/2020
Inspector: Steven Gazlay
Result: DISAPPROVED

Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG
Handrails must be between 34" and 38" measured at walkline. No answer at door. Unable to gain access.

Inspection Type: FINAL**
Scheduled Date/Time: 11/10/2020
Completed Date/Time: 11/10/2020
Inspector: Slade Burton Lawson III
Result: APPROVED

Remarks:
Notes: Customer request am

