

HTE# BRES-2005-00<sup>41</sup>

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME TRAVIS Everette PHONE # 919-291-2338

ADDRESS P.O. BOX 384 Anglen N.C. 27501

NAME OF MOBILE HOME PARK OR S/D \_\_\_\_\_

NAME OF OWNER (IF DIFFERENT) \_\_\_\_\_

ADDRESS OF OWNER (IF DIFFERENT) Physical 1118 OAK GROVE CHURCH RD Anglen N.C. 27501 lot 4

PROPERTY LOCATION: STATE ROAD NAME AND # 512 1532 OAK GROVE CHURCH RD

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

- THIS INSPECTION IS VOID IF:
- (1) the intended use of the septic system should change, and/or
  - (2) the system should fail or malfunction, and/or
  - (3) the owner or tenant of the property changes, and/or
  - (4) after six months

22x26' STORAGE BUILDING

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Mashant JR RSHS  
Signature of Inspector

6-1-20  
Date