

June 5, 2020

Angelica Aviles  
5961 Christian Light Road  
Fuquay Varina, NC 27526

**RE: Existing Tank Application # BRES2005-0049**

Ms. Aviles:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary T
- 4. Other – Uncovered tank full to lids with fluid and D-Box collapsed. Perform routine maintenance to alleviate issues and/or file for system repair with Harnett County.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy - Central Permitting