

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

*BLUES 2006-0005
 LOT 20*

Owner: *-* Applicant: *JENNIFER MILES ACCANTINI*
 Address: *TUTOR RD* Date Evaluated: *06/15/2003*
 Proposed Facility: *300 D* Design Flow (.1949): *360 GPD* Property Size: *1.0 AC*
 Location of Site: *300 D* Property Recorded: *360 GPD*
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	L 3-5%	0-30	CL LS	VLN NSMP					PS
		30-48	ML SLL	FL SSSP	7.5 YR 7.0 44"	48			0.45
3,4,5	L 3-5%	0-30	CL LS	VLN NSMP					PS
		30-48	ML SLL	FL SSSP		48			0.45

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948): <i>PROVISIONALLY SATISFACTORY</i>
System Type(s)	<i>250 GPD</i>	<i>250 GPD</i>	Evaluated By: <i>ANDREW CURRAN, 6/15</i>
Site LTAR	<i>0.45</i>	<i>0.45</i>	Others Present:

