



**Harnett County**  
 420 McKinney Pkwy  
 LILLINGTON, NC 27546  
 Phone:  
 Fax:

7/17/2024

**SUBJECT: BRES2006-0029  
 BUILDING RESIDENTIAL**

To: Wimberly Builders LLC

Here are the results of all Inspections located at **250 WOODLAND RIDGE DR:**

Inspection Type: TAX INSPECTION  
 Scheduled Date/Time:  
 Completed Date/Time:  
 Inspector: Tax Inspection  
 Result:  
 Remarks:  
 Notes:

Inspection Type: UNDER SLAB TRADES  
 Scheduled Date/Time: 6/29/2020  
 Completed Date/Time: 6/29/2020  
 Inspector: Ray Holder  
 Result: APPROVED  
 Remarks:  
 Notes:

Inspection Type: ROUGH IN  
 Scheduled Date/Time: 7/22/2020  
 Completed Date/Time: 7/22/2020  
 Inspector: Ray Holder  
 Result: DISAPPROVED  
 Remarks: eTRAKiT Inspection Request  
 Notes: 7/21/2020 1:30 PM Wimberly Builders LLC  
 Basement to left side of home. There is a back entrance at 397 Hectors Creek. You can follow the gravel road they the dark blue gate. This will bring you straight up to the garage door of the basement. Contact Tony 919-669-7066.  
 Contact Name: Wimberly Builders LLC  
 Site Address: 250 WOODLAND RIDGE DR  
 Phone: 9196697066  
 e-Mail: tony@wimberlybuilders.com

Water heater drain line needs running to exterior of home.2) plumbing test down.





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 7/27/2020  
Completed Date/Time: 7/27/2020  
Inspector: Ray Holder  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes:

Inspection Type: INSULATION  
Scheduled Date/Time: 7/27/2020  
Completed Date/Time: 7/27/2020  
Inspector: Ray Holder  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 7/25/2020 12:00 PM Wimberly Builders LLC  
Contact Tony 919-669-7066  
Contact Name: Wimberly Builders LLC  
Site Address: 250 WOODLAND RIDGE DR  
Phone: 9196697066  
e-Mail: tony@wimberlybuilders.com

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 9/30/2020  
Completed Date/Time: 9/30/2020  
Inspector: Scott Guy  
Result: DISAPPROVED  
Remarks:  
Notes: No answer at front door 9:28am

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 10/2/2020  
Completed Date/Time: 10/2/2020  
Inspector: Brad Sutton  
Result: DISAPPROVED  
Remarks:  
Notes: 1. Doors from garages to living space and HVAC closet must be sealed air tight.



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 10/8/2020  
Completed Date/Time: 10/8/2020  
Inspector: Ray Holder  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 10/6/2020 5:33 PM Wimberly Builders LLC  
Use Hector's Creek entrance.. basement door unlocked  
Contact Name: Wimberly Builders LLC  
Site Address: 250 WOODLAND RIDGE DR  
Phone: 9196697066  
e-Mail: tony@wimberlybuilders.com