

HTE# BRS 2006-0036

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME J. A. HART Construction PHONE # 919-935-2603

ADDRESS 3408 Lee Ave Sanford N.C. 27332

NAME OF MOBILE HOME PARK OR S/D Summerlin lot 28

NAME OF OWNER (IF DIFFERENT) Morgan Cowten

ADDRESS OF OWNER (IF DIFFERENT) 129 Beautiful Ln Sanford N.C. 27332

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1320

luxio Deck

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Marham HE 72848  
Signature of Inspector

6-26-20  
Date