





J.S. CONSULTING & DESIGN  
STRUCTURAL & CIVIL ENGINEERS

CERTIFICATE NUMBER: P-1513

Client:  
Superior Metal Structures & Concrete  
1183 S NC 41 & HWY 111  
Beulaville, NC 28518  
(p) 252-286-4512

Project:  
30'x45'x10'  
Joseph R. Dunn  
930 Miller Rd  
Benson, NC 27504

Job No:  
1901-1680  
Date:  
06/24/20  
Sheet:  
S1




(A) SLAB TURN DOWN  
NOT TO SCALE

DRAINAGE NOTE:  
OWNER TO PROVIDE POSITIVE  
DRAINAGE AWAY FROM BLDG. PAD.

# FOUNDATION PLAN

NOT TO SCALE






J.S. CONSULTING & DESIGN  
ARCHITECTS & ENGINEERS

CERTIFICATE NUMBER: P-1513

Client:  
Superior Metal Structures & Concrete  
1183 S NC 41 & HWY 111  
Beulaville, NC 28518  
(p) 252-286-4512

Project:  
30'x45'x10'  
Joseph R. Dunn  
930 Miller Rd  
Benson, NC 27504

Job No:  
1901-1680  
Date:  
06/24/20  
Sheet:  
S2



FRAMING PLAN  
NOT TO SCALE




B

CERTIFICATE NUMBER: P-1513


Client:  
 Superior Metal Structures & Concrete  
 1183 S NC 41 & HWY 111  
 Beulaville, NC 28518  
 (P) 252-286-4512

Project:  
 30'x45'x10'  
 Joseph R. Dunn  
 930 Miller Rd  
 Benson, NC 27504

Job No:  
 1901-1680  
 Date:  
 06/24/20  
 Sheet:  
 S3



TYPICAL CROSS SECTION B-B  
 NOT TO SCALE



TYP. WIND COLLAR/BRACE  
 NOT TO SCALE

GABLE END WALL FRAMING  
 GABLE END WALLS SHALL BE FRAMED @ 4' O.C.  
 USING 2-1/4" 14ga SQUARE TUBES TO THE  
 BOTTOM RAIL AND RAFTERS W/ L-CLIPS AND  
 (2) SCREWS IN EACH LEG OF THE CLIP. ANY  
 STUDS OVER 13'-0" IN LENGTH SHALL BE (2)  
 2-1/4" 14ga AND ATTACHED W/ (2) L-CLIPS  
 AND (2) SCREWS IN EACH LEG OF THE CLIP.





JB


CERTIFICATE NUMBER: P-1513

Client:  
Superior Metal Structures & Concrete  
1183 S NC 41 & HWY 111  
Beaufort, NC 28518  
(p) 252-286-4512

Project:  
30'x45'x10'  
Joseph R. Dunn  
930 Miller Rd  
Benson, NC 27504

Job No:  
1901-1680  
Date:  
06/24/20  
Sheet:  
S4

SEE FRAMING PLAN FOR SPACING



SIDE ELEVATION  
NOT TO SCALE

**DOOR OPENING NOTE:**  
FOR DOORS PLACED IN GABLE END WALLS ONLY. EXACT LOCATION TO BE DETERMINED BY BUILDER. MINIMUM HEADER SIZE (2) 2-1/4" 14ga SQUARE TUBES ATTACHED TOGETHER W/ CLIPS AND SCREWS @ 1'-0" O.C. MINIMUM (1) 2-1/4" KING STUD EACH SIDE FOR DOORS LESS THAN 10' WIDE AND (2) 2-1/4" KING STUD EACH SIDE FOR DOORS 12' AND WIDER. ATTACH USING ANGLE CLIPS AND SCREWS

ALL ANGLE CLIPS TO HAVE (2) SCREWS INSTALLED IN EACH LEG OF ANGLE. TYP.





J.S. CONSULTING & DESIGN  
STRUCTURAL ENGINEERING

Client:  
Superior Metal Structures & Concrete  
1183 S NC 41 & HWY 111  
Beulaville, NC 28518  
(p) 252-286-4512

Project:  
30'x45'x10'  
Joseph R. Dunn  
930 Miller Rd  
Benson, NC 27504

Job No:  
1901-1680  
Date:  
06/24/20  
Sheet:  
S5

CERTIFICATE NUMBER: P-1513

### NOTES

#### DESIGN CRITERIA

1. BUILDING CODE.....2018 NORTH CAROLINA BUILDING CODE
2. IMPORTANCE FACTORS    SNOW (Is)    0.80  
   SEISMIC (Iw)    1.0
3. GROUND SNOW LOAD.....10 PSF
4. ROOF LL.....5 PSF (NO FOOT TRAFFIC)
5. WIND
  - A) ULTIMATE WIND SPEED (IBC) .....120 MPH
  - B) NOMINAL WIND SPEED (ASCE 7-10) .....93 MPH
  - C) WIND HAZARD EXPOSURE CATEGORY.....B
  - D) WIND BASE SHEARS (for MWFRS)     $V_x = 2.4 \text{ k}$      $V_y = 2.4 \text{ k}$  (PER FRAME)
6. SEISMIC
  - A) SEISMIC DESIGN CATEGORY A  
COMPLIANCE WITH SECTION 1616.4 ONLY?     YES     NO
  - B) SEISMIC DESIGN CATEGORY     B     C     D

SEISMIC USE GROUP    1  
SPECTRAL RESPONSE ACCELERATION     $S_e$  19.6 %g     $S_1$  7.3 %g  
SITE CLASSIFICATION D    FIELD TEST     PRESUMPTIVE     HISTORICAL DATA  
BASIC STRUCTURAL SYSTEM (CHECK ONE)  
 BEARING WALL     DUAL W/SPECIAL MOMENT FRAME  
 BUILDING FRAME     DUAL W/INTERMEDIATE R/C OR SPECIAL STEEL  
 MOMENT FRAME     INVERTED PENDULUM  
SEISMIC BASE SHEAR     $V_x = 0.5 \text{ k}$      $V_y = 0.5 \text{ k}$  (PER FRAME)

ANALYSIS PROCEDURE  SIMPLIFIED     EQUIVALENT LATERAL FORCE     MODAL  
ARCHITECTURAL, MECHANICAL, COMPONENTS ANCHORED?     NO  
LATERAL DESIGN CONTROL: EARTHQUAKE     WIND

#### OTHER NOTES

1. PRESUMPTIVE SOIL PRESSURE = 1,500 PSF.
2. WHERE A DETAIL IS SHOWN ON STRUCTURAL DRAWINGS FOR ONE CONDITION, IT SHALL APPLY TO ALL SIMILAR OR LIKE CONDITIONS, UNLESS NOTED OR SHOWN OTHERWISE.
3. IF CONTRACTOR FINDS A DIFFERENCE BETWEEN THESE DRAWINGS AND EXISTING ELEVATIONS, OR OTHER CONDITIONS WHICH PROHIBIT EXECUTION OF THE WORK AS DIRECTED ON THESE DRAWINGS, CONTRACTOR SHALL NOTIFY ENGINEER IMMEDIATELY.
4. ALL ITEMS SHALL BE TIGHTLY ANCHORED OR ATTACHED SQUARE, PLUMB AND TRUE, OR IN OTHER PLANES OR SHAPES AS SHOWN ON THE DRAWINGS. JOINTS SHALL BE TIGHT, EVEN, AND FREE OF OFFSETS. NO FIELD ALTERING OF ANY MEMBERS WILL BE ALLOWED THAT WILL CAUSE THEM NOT TO BE IN ACCORDANCE WITH THE DRAWINGS AND THEM NOT TO BE IN ACCORDANCE WITH THE DRAWINGS AND SPECIFICATIONS, WITHOUT WRITTEN APPROVAL OF THE DESIGN ENGINEER.
5. GENERAL CONTRACTOR IS RESPONSIBLE TO PROVIDE ADEQUATE SHORING, BRACING OR SUPPORT TO PREVENT MOVEMENT, SETTLEMENT, OR DAMAGE TO THE STRUCTURE DURING CONSTRUCTION PROCEDURES ASSOCIATED WITH THIS PROJECT.
6. CONCRETE: CONCRETE MINIMUM COMPRESSIVE STRENGTH AT 28 DAYS SHALL BE 3000 PSI.
7. CONCRETE WORK SHALL COMPLY WITH ACI SPECIFICATIONS FOR STRUCTURAL CONCRETE FOR BUILDING (ACI 301) AND APPLICABLE PROVISIONS OF ACI 318. KEEP A COPY OF ACI FIELD REFERENCE MANUAL (ACI-SP-15) WHICH INCLUDES ACI 301 AND OTHER ACI AND ASTM REFERENCES ON THE JOB.
8. ALL FOOTING FOUNDATIONS SHALL BE PLACED ON COMPETENT SOIL.
9. FIBER MESH MAY BE SUBSTITUTED FOR WWM PER MANUFACTURER'S RECOMMENDATIONS.
10. REINFORCING STEEL: ASTM A615, GRADE 60. PROVIDE 3" CLEARANCE TO EARTH SURFACES. LAP BARS 30 DIAMETERS.
11. ALL GALVANIZING SHALL BE PERFORMED AFTER FABRICATION, AND IN ACCORDANCE WITH ASTM A123 AND/OR A153.
12. THE MINIMUM YIELD STRENGTH OF THE STEEL USED IN THE LIGHT GAUGE METAL FRAMES SHALL BE 55,000 PSI, FOR RAW OR GALVANIZED TUBES.
13. THE MINIMUM YIELD STRENGTH OF THE STEEL USED FOR THE LIGHT GAUGE METAL DECK SHALL BE 80,000 PSI, DECKING PANELS SHALL COVER THREE SPANS, MINIMUM.
14. THE LIGHT GAUGE METAL FRAMES AND DECK SHALL BE OF THE GAUGE INDICATED ON THE PLAN/DETAILS.
15. ALL SCREWS FOR ASSEMBLING FRAMES SHALL BE #12 SIZE.
16. ALL WELDING SHALL BE IN ACCORDANCE WITH AWS D1.1.
17. ALL WELDS SHALL BE COATED WITH GALVANIZE PRIMER & PAINT AFTER WELDING.

