



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

6/8/2021

SUBJECT: BRES2006-0058
BUILDING RESIDENTIAL

To: Highland Construction Company

Here are the results of all Inspections located at **175 ROLLING PINES DR:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: T-POLE
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 7/22/2020
Completed Date/Time: 7/22/2020
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks: all trades included
Notes: lock box 6738



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 8/11/2020
Completed Date/Time: 8/11/2020
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: lock box 6738
Insulation around windows not complete

Inspection Type: INSULATION
Scheduled Date/Time: 8/21/2020
Completed Date/Time: 8/21/2020
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: lock box code 6738

Inspection Type: POLE
Scheduled Date/Time: 8/27/2020
Completed Date/Time: 8/27/2020
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: T-POLE
Scheduled Date/Time: 9/21/2020
Completed Date/Time: 9/21/2020
Inspector: Slade Burton Lawson III
Result: CANCELLED
Remarks:
Notes: Power Co made him move pole and needs reinspection

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 1/19/2021
Completed Date/Time: 1/19/2021
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks: lock box is 6738
Notes: Missing face plates throughout, no cover house panel garage





Harnett County
108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: TEMP POWER CERTIFICATION

Scheduled Date/Time: 1/28/2021

Completed Date/Time: 1/28/2021

Inspector: Slade Burton Lawson III

Result: APPROVED

Remarks: lock box is 6738

Notes: