



Permit Inspections Harnett County

Permit Number: BRES2006-0058

Description: Fire Renovation **permit includes all trades**

Applied: **6/22/2020**

Approved: **7/15/2020**

Site Address: **175 ROLLING PINES DR**

Issued: **7/16/2020**

Finalized: **6/21/2021**

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **FINALED**

Applicant: **Highland Construction Company**

Parent Permit:

Owner: **KINZER KATHIE LAVELL**

Parent Project:

Contractor: **Highland Construction Company**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FOUNDATION	Slade Burton Lawson III		
Notes:						
			T-POLE	Slade Burton Lawson III		
Notes:						
	7/22/2020	7/22/2020	ROUGH IN	Slade Burton Lawson III	APPROVED	all trades included
Notes: lock box 6738						
	8/11/2020	8/11/2020	INSULATION	Slade Burton Lawson III	DISAPPROVED	
Notes: lock box 6738 Insulation around windows not complete						
	8/21/2020	8/21/2020	INSULATION	Steven Gazlay	APPROVED	
Notes: lock box code 6738						
	8/27/2020	8/27/2020	POLE	Slade Burton Lawson III	APPROVED	
Notes:						
	9/21/2020	9/21/2020	T-POLE	Slade Burton Lawson III	CANCELLED	
Notes: Power Co made him move pole and needs reinspection						





Permit Inspections Harnett County

	1/19/2021	1/19/2021	TEMP POWER CERTIFICATION	Slade Burton Lawson III	DISAPPROVED	lock box is 6738
Notes: Missing face plates throughout, no cover house panel garage						
	1/28/2021	1/28/2021	TEMP POWER CERTIFICATION	Slade Burton Lawson III	APPROVED	lock box is 6738
Notes:						
	6/10/2021	6/10/2021	FINAL**	Slade Burton Lawson III	DISAPPROVED	
Notes: sbl changed Inspection Date/Time from 06/09/2021 to 06/10/2021 Chi;d safety locks 2nd floor windows where less than 24" above finished floor						
	6/21/2021	6/21/2021	FINAL**	Slade Burton Lawson III	APPROVED	
Notes:						

