Harnett County Department of Public Health


Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: John Avis	SUBDIVISION	Heloli IIII Ku (SK #1)	LOT #	
NEW REPAIR EXPANSION		quired prior to Construction Authorizat		
Type of Structure: DWMH 32'x76'		quite prior to construction numerical	TOTAL	
Proposed Wastewater System Type: 25% Reduction				
Projected Daily Flow: 480 GPD				
Number of bedrooms: 4 Number of Occupants:	8max			
Basement Yes X No				
	ased on final location and elevations of facilities			
Type of Water Supply: Community Public 🗵	Well Distance from well 50+ feet	Permit valid for:	▼ Five years	
Permit conditions:			No expiration	
111 011	,			
Authorized State Agent:	RE7-18-I Date: 7/14/2020	SEE ATTACH	HED SITE SKETCH	
The issuance of this permit by the Health Department in no way guarantees th	ne issuance of other permits. The permit holder is responsible for ch	cking with appropriate governing bodies in me	eeting their requirements. This	
site is subject to revocation if the site plan, plat, or the intended use changes.	. The Improvement Permit shall not be affected by a change in own	ership of the site. This permit is subject to com	npliance with the provisions of	
the Laws and Rules for Sewage Treatment and Disposal and to conditions of th	is permit.			
	Construction Authorization			
	Construction Authorization			
	(Required for Building Permit)			
The construction and installation requirements of Rules 1950, 1952, 1954, 19 with the attached system layout.	955, .1956, .1957, .1958. and .1959 are incorporated by references	into this permit and shall be met. Systems sha	all be installed in accordance	
with the attached system layout.				
ISSUED TO: John Avis	PROPERTY LOCATION: 2509	Cameron Hill Rd (SF	R#1108)	
	SUBDIVISION		LOT #	
Facility Type: DWMH 32'x76'	New □ Expansion □ Repair			
Basement? Yes No Basement Fixtures?				
Type of Wastewater System** 25% Reduction		(Initial) Wastewater Flow: 48	BO GPD	
(See note below, if applicable)				
25% Reduction	n (Repair)			
	mber of trenches 2			
	act length of each trench 100 feet	Trench Spacing: 9 Fe	eet on Center	
,	nches shall be installed on contour at a	Soil Cover: 6inch		
,	ximum Trench Depth of: 18-24 inches	(Maximum soil cover shall not		
	ench bottoms shall be level to +/-1/4"	36" above the trench bottom		
1	all directions)	30 above the trenen bottom	'/	
Pump Requirements:ft. TDH vsGP			inches below pipe	
rump negarientsn. 1011 vsu	11	Aggregate Depth:		
Conditions:		Aggregate Deptil.	inches above pipe	
Conditions.			inches total	
WATER LINES (INCLUDING IRRIGATION) MILET RE 30	TT FROM ANY PART OF SERVIC SYSTEM OR	ACDAID ADCA		
WATER LINES (INCLUDING IRRIGATION) MUST BE 10		CEPAIK AKEA.		
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN	I FIELD AKEA.			
**If applicable: I understand the system type specified is di	ifferent from the type specified on the application	I accept the specifications of this	permit.	
Owner/Legal Representative Signature:		Date:		
This Construction Authorization is subject to revocation if the site plan, plat, or	the intended use changes. The Construction Authorization shall not	pe transferred when there is a change in owner	rship of the site. This	
Construction Authorization is subject to compliance with the provisions of the La	uws and Rules for Sewage Treatment and Disposal and to the condit	ons of this permit. SEE ATI	TACHED SITE SKETCH	
1 M C	/ -			
Authorized State Agent: Date: 7/14/2020				
Construction Authorization Expiration Date: 7/14/2025				
	The state of the s			

Harnett County Department of Public Health Site Sketch

Property Location: 2509 Cameron Hill IZCI	
Issued To: JOHN AMS Subdivision	Lot #
Authorized State Agent: Both All REHS-T	Date: 7/14/2020



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.