

To whom it may concern,

I, D. Keith Lassiter have inspected the electrical system and wiring at the 88 Colby Lane Angier, NC addition. The Electrical system includes the following:

200 amp split service. 200 amp Meter/Panel combo on the exterior, 100 amp sub-panel in interior

2- 20 amp GFI circuits in kitchen

240V/40 amp circuit for range

240/30 amp circuit for dryer

240/30 amp circuit for water heater

240/60 & 240/30 amp circuits for Electric Package HVAC unit

20 amp dedicated circuit for washer

20 amp dedicated circuit for refrigerator

20 amp dedicated circuit for micro/hood

20 amp dedicated circuit for bathroom outlets – 3 total

120/15 amp circuits for lights and bedrooms

3 Outdoor GFI outlets

Smoke & Carbon detectors inside and outside the bedrooms

The electrical system and wiring is in excellent condition, shows signs of quality work and meets or exceeds the National Electrical code for the year 2011.

Feel free to contact me with any questions.

Keith Lassiter

NC Electrical License # 18162

919-397-7327



6-24-2020