

# Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

195 King Charles Ave

ISSUED TO: Winding Ridge Properties, Inc  
NEW  REPAIR  EXPANSION

PROPERTY LOCATION: JR 1105 McCoy Town RD  
SUBDIVISION: Knottingham MHP LOT # 20

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SWMH  
Proposed Wastewater System Type: 25% REDUCTION

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet

Permit valid for:  Five years  
 No expiration

Permit conditions: \_\_\_\_\_

Authorized State Agent: James E. Marshall Date: 7-30-20 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

185 King Charles Ln

ISSUED TO: Winding Ridge Properties, Inc

PROPERTY LOCATION: JR 1105 McCoy Town RD  
SUBDIVISION: Knottingham MHP LOT # 20

Facility Type: SWMH  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* 25% REDUCTION System (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable  25%/50% REDUCTION (Repair)

### Installation Requirements/Conditions

Septic Tank Size 1000 gallons  
Pump Tank Size \_\_\_\_\_ gallons

Number of trenches 2  
Exact length of each trench 80 feet  
Trenches shall be installed on contour at a  
Maximum Trench Depth of: 22-218 inches  
(Trench bottoms shall be level to +/- 1/4" in all directions)

Trench Spacing: 9 Feet on Center  
Soil Cover: 6 inches  
(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM  
Aggregate Depth: 6 inches below pipe  
2 inches above pipe  
12 inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_


This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Marshall Date: 7-30-20  
Construction Authorization Expiration Date: 7-30-25

Application # BLPS 2007-0035

### Harnett County Department of Public Health Site Sketch

Property Location: SR 1105 MCKAY TOWN RD 185 King Charles Ave  
Issued To: Winding Ridge Properties Inc Subdivision Knott Farm 1114P Lot # 20  
Authorized State Agent: James E. Marshall III PLS Date: 7-30-20



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.