

Permit Inspections Harnett County

Permit Number: BRES2007-0045

Description: 15x21 B. Room finished w/out permits

Applied: 7/16/2020	Approved: 7/16/2020	Site Address: 190 OMAHA DR
Issued: 7/17/2020	Finaled: 7/27/2020	City, State Zip Code: BROADWAY, NC 27505
Status: FINALED		Applicant: BRUNER BRANDON L
Parent Permit:		Owner: BRUNER BRANDON L
Parent Project:		Contractor: <none></none>

Details:

LIST OF INSPECTIONS						
SEQ ID	SCHEDULED DATE	COMPLETED DATE	ТҮРЕ	INSPECTOR	RESULT	REMARKS
			ENVIR OPERATIONS PERMIT	EH Bucket		
Notes:						
			FOOTING	Slade Burton Lawson III		
Notes:						
			FOUNDATION	Slade Burton Lawson III		
Notes:						
			INSULATION	Slade Burton Lawson III		
Notes:						
			MONO SLAB	Slade Burton Lawson III		
Notes:						
			OPEN FLOOR	Slade Burton Lawson III		
Notes:						
			ROUGH IN	Slade Burton Lawson III		
Notes:						





Permit Inspections

Harnett County

			SLAB	Slade Burton Lawson III				
Notes:								
			TAX INSPECTION	Tax Inspection				
Notes:								
			UNDER SLAB TRADES	Slade Burton Lawson III				
Notes:				-	-			
			FINAL**	Slade Burton Lawson III				
Notes:				-	-			
	7/20/2020	7/20/2020	FINAL**	Slade Burton Lawson III	DISAPPROVED			
Notes:								
lock box 4640								
Need documentation from licensed Electrician and HVAC company stating all work was done per 2018 NCBC								
	7/24/2020	7/24/2020	FINAL**	Slade Burton Lawson III	DISAPPROVED			
Notes:								
Additior	n must be on gfi circuit							
	7/27/2020	7/27/2020	FINAL**	Slade Burton Lawson III	APPROVED			
Notes:								
Work completed in 2013 per homeowner.								

