



Permit Inspections Harnett County

Permit Number: BRES2007-0046

Description: 24x62 commercial modular being made a residential modular

Applied: **7/16/2020**

Approved: **10/15/2020**

Site Address: **93 POINSETTIA LN**

Issued: **10/19/2020**

Finalized: **2/10/2021**

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **FINALED**

Applicant: **WEST CLARISTA**

Parent Permit:

Owner: **WEST CLARISTA**

Parent Project:

Contractor: **WEST CLARISTA**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FOOTING	Steven Gazlay		
Notes:						
			FLOOR FRAMING	Steven Gazlay		
Notes:						
			INSULATION	Steven Gazlay		
Notes:						
			ROUGH IN	Steven Gazlay		
Notes:						
			T-POLE	Steven Gazlay		
Notes:						
			TEMP POWER CERTIFICATION	Steven Gazlay		
Notes:						
	11/18/2020	11/18/2020	ADDRESS	GIS Bucket	APPROVED	
Notes: 93 POINSETTIA LN SPRING LAKE 28390.						
	12/17/2020	12/18/2020	FOUNDATION	Unassigned	DISAPPROVED	
Notes: Inspector SPG changed the inspection assignment from SPG to SBL Need engineer letter on footings and piers, marriage wall ok, plumbing connections ok, electrical rough in not complete, ok to side ends of modular.						
	1/19/2021	1/19/2021	FOUNDATION	Unassigned	DISAPPROVED	
Notes:						





Permit Inspections Harnett County

	2/2/2021	2/2/2021	MARRIAGE WALL	Unassigned	APPROVED	
--	----------	----------	---------------	------------	----------	--

Notes:
Inspector SPG changed the inspection assignment from SPG to SBL

	2/10/2021	2/10/2021	FOUNDATION	Unassigned	APPROVED	
--	-----------	-----------	------------	------------	----------	--

Notes:

	2/10/2021	2/10/2021	MODULAR FINAL**	Unassigned	APPROVED	
--	-----------	-----------	--------------------	------------	----------	--

Notes:

