

August 26th, 2020

ph: 910-893-7547

fax: 910-893-9371

Ethan Kennon  
220 S White Street Suite 6  
Wake Forest, NC 27587

**RE: Existing Tank Application # BRES2008-0017- 40 Wyndham Place Dr, Fuquay Varina**

Mr. Kennon,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary T
- 4. Other – Septic Encroachment - Proposed garage encroaches on existing septic system. Unable to approve. System flagged onsite and located by GPR. Garage must be shifted back to be behind septic area (revision required).**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

AC/kh  
Copy - Central Permitting