

September 8, 2020

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

James Elmore
40 Farmridge Court
Angier, NC 27501

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: BRES2008-0037

Mr Elmore:

An attempt was made to evaluate your property for the purpose of issuing a permit for relocation. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- **All or part of drain line is required to be relocated to accommodate rear pool. Drain lines were located via GPR. Applicant explained options and soil checked in relocation areas. Applicant instructed to uncover outlet end of tank, locate property irons, and mark property lines to verify available space. Reconfirm with EH. Revision of pool location with Central Permitting required at some point in time but verification of final drain line location can be determined first.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting