

HTE #: BRES2008-0046

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Billings Construction Inc. Phone #: (919) 592-4574

Address: 4504 Greenbreeve Lane Fuquay Varina, NC 27526

Name of Mobile Home Park or S/D: Legacy at Rawls - Lot 28

Name of Owner (if different): Howard Ginsburg

Address of Owner (if different): 32 Oakbluff Ct. Fuquay-Varina, NC 27526

Property Location (State Road name and #): 32 Oakbluff Ct. (Rawls Church Rd. - SR 1415)

Purpose of Inspection: 23'x28' Detached Garage


The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

09/01/2020

Date