

September 16th, 2020

ph: 910-893-7547

fax: 910-893-9371

Sharon Stewart
170 Kathleen Terrace
Sanford, NC 27332

RE: Existing Tank Application # BRES2008-0076- 19 Georgia Way Cameron NC

Ms. Stewart,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

X **3. Replace Sanitary with Filter**

X **4. Other – House needs to be placed where original house was. Must be 5' minimum off of septic.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart III, R.E.H.S.
Environmental Health Program Specialist
Harnett County Department of Public Health

JEM/kh
Copy - Central Permitting