

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: <input checked="" type="radio"/> Y <input type="radio"/> N	Commercial Project: <input type="radio"/> Y <input type="radio"/> N
Code Enforcement Project No:	Permit No: BRES2009-0022
Project Name: Residential Addition	Owner: Anthony & Michele Miller
Project Address: 8296 Christian Light Rd. Fuquay-Varina, NC	Suite No:
Date Inspected: 11-24-2020	Contractor Name: Anthony Miller
Component Inspected: Foundation	

Responsible Licensed NC Architect or NC Engineer

Name:	Mark E. Jones, PE
Firm Name:	
Phone Numbers:	Office: Mobile: 919-395-5618
Email Address:	mejpe@nc.rr.com
Mailing Address:	6425 Glen Dean Ct. Raleigh, NC 27603

APPLICABLE CODE: 2018 NCRC


2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: *Foundation, including perimeter walls and interior piers. All masonry was plumb and level with joints filled with mortar. Top courses were solid block with anchor bolts installed. Projection was adequate in all locations. Note field construction varies from approved design plans. The field conditions have been reviewed and approved. The foundation met the requirements of the 2018


*(subgrade form/letter may also be required)
NC Residential Building Code and was approved.

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.



Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.