



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

12/13/2023

SUBJECT: BRES2009-0022
BUILDING RESIDENTIAL

To: MILLER ANTHONY R

Here are the results of all Inspections located at **8296 CHRISTIAN LIGHT RD:**

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: TAX INSPECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Tax Inspection
Result:
Remarks:
Notes:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 11/30/2020
Completed Date/Time: 11/30/2020
Inspector: Ray Holder
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/24/2020 4:24 PM Anthony Miller

Contact Name: Anthony Miller
Site Address: 8296 CHRISTIAN LIGHT RD
Phone: 9198306850
e-Mail: millerar68@gmail.com

Foundation inspection has to pass before I can approve open floor inspection.

Inspection Type: FOUNDATION
Scheduled Date/Time: 11/30/2020
Completed Date/Time: 11/30/2020
Inspector: Ray Holder
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/24/2020 4:23 PM Anthony Miller

Contact Name: Anthony Miller
Site Address: 8296 CHRISTIAN LIGHT RD
Phone: 9198306850
e-Mail: millerar68@gmail.com

Footings have to pass before I can approve foundation.

Inspection Type: FOOTING
Scheduled Date/Time: 11/30/2020
Completed Date/Time: 11/30/2020
Inspector: Ray Holder
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/24/2020 4:23 PM Anthony Miller

Contact Name: Anthony Miller
Site Address: 8296 CHRISTIAN LIGHT RD
Phone: 9198306850
e-Mail: millerar68@gmail.com

Need engineer letter for footings that have no been inspected according to permit.



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION
Scheduled Date/Time: 12/1/2020
Completed Date/Time: 12/1/2020
Inspector: Ray Holder
Result: APPROVED
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 12/1/2020
Completed Date/Time: 12/1/2020
Inspector: Ray Holder
Result: APPROVED
Remarks:
Notes:

Inspection Type: FOOTING SFD CRAWL
Scheduled Date/Time: 12/1/2020
Completed Date/Time: 12/1/2020
Inspector: Ray Holder
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 2/8/2021
Completed Date/Time: 2/8/2021
Inspector: Ray Holder
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 2/5/2021 12:29 PM Anthony Miller

Contact Name: Anthony Miller
Site Address: 8296 CHRISTIAN LIGHT RD
Phone: 9198306850
e-Mail: millerar68@gmail.com

Missing insulation baffles and washer box needs to be at 35" from finished floor.



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 6/2/2021 AM
Completed Date/Time: 6/2/2021
Inspector: Ray Holder
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/31/2021 11:09 PM Anthony Miller

Contact Name: Anthony Miller
Site Address: 8296 CHRISTIAN LIGHT RD
Phone: 9198306850
e-Mail: millerar68@gmail.com

Inspection Type: FINAL**
Scheduled Date/Time: 8/30/2022
Completed Date/Time: 8/30/2022
Inspector: Justin Ryan McLeod
Result: DISAPPROVED
Remarks:
Notes: Will need glass in window by the rear door