

HTE# B1052009-0052

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Alexia Dewane PHONE # 920-254-5310

ADDRESS 5535 Butler Nursery Rd Fayetteville N.C. 28306

NAME OF MOBILE HOME PARK OR S/D Summerlens Lot 53 ^{43 whiteclayton}

NAME OF OWNER (IF DIFFERENT) Procession Custom Homes and Renovations LLC

ADDRESS OF OWNER (IF DIFFERENT) _____

PROPERTY LOCATION: STATE ROAD NAME AND # 201320 Milton Welch RD

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

12x24 Prefab wood
SHED

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Marshall JR RBMS
Signature of Inspector

10-5-20
Date