



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

7/30/2024

SUBJECT: BRES2009-0052
BUILDING RESIDENTIAL

To: Alexia Dewane

Here are the results of all Inspections located at **43 WHITE CLOUD LN:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 11/30/2020
Completed Date/Time: 11/30/2020
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Anchor building at each corner. Turn 1 block to its strength axis(block can't be on it side).

