

# SanLee Environmental, LLC

Project: Onesimus Tavoc Date: 11/23/2020  
Address: 55 Bighorn Lane, Sanford, NC  
County: Harnett PIN# \_\_\_\_\_ Water Source: Public Water  
Number of Bedrooms: 3 Design Daily Flow: 360 gpd Waste Strength: Domestic

## Initial System

LTAR: 0.25 Trench Width: 3 Trench Depth: 8"  
Min ft of Drainfield 480 % Reduction: 0 Adjusted ft of Drainfield: 0  
Size of Septic Tank: 1000 Gallons Size of Pump Tank: NA Gallons  
Distribution Method: Serial Specified Product: Low Profile Chamber  
Pretreatment Required: NA Soil Cover Required: 6"

### Notes

- 1) Install system at 8" as measured on the downslope side
- 2) Additional soil may be required to ensure 6" of soil cover is maintained\
- 3) Care should be taken to avoid driving over any portion of the septic system
- 4) Last modification to property occurred in 1976 and is repair exempt (per register of deeds)

## Repair System

LTAR: \_\_\_\_\_ Trench Width: \_\_\_\_\_ Trench Depth: \_\_\_\_\_  
Min. ft of Drainfield \_\_\_\_\_ % Reduction: \_\_\_\_\_ Adjusted ft of Drainfield: \_\_\_\_\_  
Size of Septic Tank: \_\_\_\_\_ Gallons Size of Pump Tank: \_\_\_\_\_ Gallons  
Distribution Method: \_\_\_\_\_ Specified Product: \_\_\_\_\_  
Pretreatment Required: \_\_\_\_\_ Soil Cover Required: \_\_\_\_\_

### Notes

**Project:** Onesimus Tavoc  
**Location:** 55 Bighorn Lane  
Sanford, NC

<b>Line #</b>	<b>Use</b>	<b>Color</b>	<b>Layout Line Length (ft)</b>	<b>Utilized Primary System (ft)</b>
Line 1	Initial System	Green	82	68
Line 2	Initial System	Red	138	136
Line 3	Initial System	Blue	154	152
Line 4	Initial System	Green	124	124
<b>Total</b>			<b>498</b>	<b>480</b>



# SanLee Environmental

Phone: 919-842-6263  
SanLeeEnvironmental@gmail.com

Project:  
55 Bighorn Lane  
Sanford, NC

Date:  
November 23, 2020

<u>Soil Borings</u>	
<18"	●
18" - 20"	●
20" - 24"	●
24" - 36"	●

  

Drainfield Line	—
Setback Line	- - -

Drawn By:  
Sloan Griffin

1" = 50'