

OPERATIONS PERMIT

Name: (owner) Patrick K. Hatrick New Installation Septic Tank
 Property Location: SR# Wheeler Dr. Repairs Nitrification Line
 Subdivision Ac. 11/2 Creek Farm * Attempt to Repair
 Lot # 40
 TAX ID# _____ Quadrant # _____
 Contractor: Gerald Teple Registration # _____


Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other Pump to Convent. and
 Size of tank: Septic Tank: Exsty gallons Pump Tank: 1000 gallons
 Subsurface Drainage Field No. of ditches 3 exact length of each ditch 110 ft. width of ditches 3 ft. depth of ditches 18-24 in.
 French Drain: _____ Linear feet

PERMIT NO. 19306

Date: 9/10/2007
 Inspected by: Bryan McSwain R.S.
 Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Patrick K. Hetrick New Installation Septic Tank
Property Location: SR# Wheeler Dr. Repairs Nitrification Line

** Attempt to Repair*

Subdivision Acilla's Creek Farms Lot # 40

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: Existing Lot Size: 3 Ac.

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 min ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other Pump to Convent. and

Size of tank: Septic Tank: existing gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 30-36 in.

French Drain Required: _____ Linear feet

Date: 7/2/2003

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature]
Environmental Health Specialist

- * Maintain all setbacks
- * Use a Ball Run Valve between septic tank + old "O" Box + connect to pump tank
- * Contractor to meet on-site prior to installing system

