

HTE #: BRES2010-0002

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Casey Kerley Phone #: (919) 922-5898

Address: 258 Willowcroft Ct Dunn, NC 28334

Name of Mobile Home Park or S/D: Leigh Laurel - Lot 7

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 258 Willowcroft Ct. (Fairground Rd. - SR 1705)

Purpose of Inspection: 18'x37' Inground Pool

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

10/14/2020

Date