

CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Hawley Builders New Installation Septic Tank
Property Location: SR# Hwy 27 Repairs Nitrification Line
Subdivision Stoney Creek Manor II Lot # 135
Contractor: Ted Brown Registration # 14

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: _____ ft.


Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface Drainage Field No. of ditches 2 exact length of each ditch 60 ft. width of ditches 3 ft. depth of ditches 18-24 in.
French Drain: _____ Linear feet

PERMIT NO. 7901

Date: 18 November, 1993
Inspected by: Paul A. [Signature]

Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Howley Builders New Installation Septic Tank
Property Location: Lot # 135 Stoney Creek Manor II, Pineview Repairs Nitrification Line

Number of Bedrooms Proposed: 3 Lot Size: ~100

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 100' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of 2 exact length 60 width of 3 depth of 24 in.
ditches of each ditch ft. ditches in.

French Drain required: — Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 7-19-93
Signed: Hal Owen

Environmental Health Specialist

VOID AFTER 5 YEARS

