

# OPERATIONS PERMIT


Name: (owner) John & Joan McCullough  New Installation  Septic Tank  
 Property Location: SR# HWY 27  Repairs  Nitrification Line  
 Subdivision Stoney Creek Manor Lot # 135  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Lonnie Johnson Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:  Attempt to Repair  
 Water Supply:  Well  Public  Community  
 Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: existing gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field: No. of ditches 1 exact length of each ditch 240 ft. width of ditches 3 ft. depth of ditches 18-24 in.  
 French Drain: \_\_\_\_\_ Linear feet

PERMIT NO. 14401 Date: 4-11-01  
 Inspected by: Joe Williams  
 Environmental Health Specialist



Replaces Permit # 13343

Keep

HARNETT COUNTY HEALTH DEPARTMENT

No 14401

IMPROVEMENT PERMIT

Attempt to Repair

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) John & Joan M<sup>rs</sup> Culbough  New Installation  Septic Tank

Property Location: SR# HWI 27  Repairs  Nitrification Line

181 Glenn Oak Drive

Subdivision Stoney Creek Manor Lot # 135

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: 150 x 190 x 110 x 165

Basement with Plumbing:  Garage:  1997 water usage was

Water Supply:  Well  Public  Community 480 gal/day

Distance From Well: \_\_\_\_\_ ft. LTAR 7

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: Existing gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 60 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain Required: \_\_\_\_\_ Linear feet

Date: 6-15-98

This permit is subject to revocation if site plans or intended use change.

Signed: J. Waters Environmental Health Specialist

OFFICE COPY

