Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID: Lot #: File #:

Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Appli	cant: SiEven Fi	~~		
Address:	Date Ev	aluated:		
Proposed Facility: 101	Watt Design	Flow (.1949):	Property Size:	
Location of Site: Sott	naver Property	Recorded:	4-1 427 122	
water suppry.	P rublic indi		☐ Spring	Other
Evaluation Method: A		☐ Pit ☐ Cu	The same of the sa	
Type of Wastewater:	Sewage	☐ Industrial Process	☐ Mixed	

P R O F I .1940			SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
L Landscape E Position/ # Slope %	Landscape Position/ Slope %	Depth (In.)	.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
34	L-	0 18	SL	FLER NONP					
		18-32	scing	FILER NON?	28"-30" 7.54,		2 112 2		05
			-						

Description	Initial	Repair System	Other Factors (.1946):
•	System	/	Site Classification (.1948): [25]
Available Space (.1945)		V	Evaluated By: 176
System Type(s)	25%	25%	Others Present:
Site LTAR	63	.3	

COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

IV SIC-SILTY CLAY 0.4 - 0.1 C-CLAY SC-SANDY CLAY

STRUCTURE SG-SINGLE GRAIN M- MASSIVE CR-CRUMB GR-GRANULAR

SLIGHTLY EXPANSIVE EXPANSIVE

MINERALOGY

GR-GRANULAR SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY PL-PLATY

