

#129

MASON Hill
 lots #129

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 2-5%	0-4	LS(A) Gr	Fr/NS/NP/NXP	>48" to				PS
		4-19	SL Gr	Fr/NS/NP/NXP	chroma 2	>48"	—	—	.5
		19-48	SCI SBk	Fi/SS/SP/SXP	Water moving through soil @ ~30"				<u>III</u>
2	L 2-5%	0-4	LS(A) Gr	Fr/NS/NP/NXP	- >48" to				PS
		4-18	SL Gr	Fr/NS/NP/NXP	chroma 2	>48"	—	—	.5
		18-48	SCI SBk	Fi/SS/SP/SXP	Water moving through soil @ ~30"				<u>III</u>
3	L 2-5%	0-4	LS(A) Gr	Fr/NS/NP/NXP	>48" to				PS
		4-28	SL Gr	Fr/NS/NP/NXP	chroma 2	>48"	—	—	.5
		28-48	SCI SBk	Fi/SS/SP/SXP	Water moving through soil @ ~32"				<u>III</u>
4	L 2-5%	0-4	LS(A) Gr	Fr/NS/NP/NXP	2.5Y 7/1 @ 42"				PS
		4-29	SL Gr	Fr/NS/NP/NXP	Water moving	>48"	—	—	.5
		29-48	SCI SBk	Fi/SS/SP/SXP	Through soil @ ~30"				<u>III</u>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: M. B. ... R.E.H. Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	258122	258122	
Site LTAR	.5	.5	

COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTLY STICKY
S-SHOULDER SLOPE L-LINEAR SLOPE		LS-LOAMY SAND			
FS-FOOT SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY
N-NOSE SLOPE H-HEAD SLOPE		L-LOAM			
CC-CONCLAVE SLOPE	III	SI-SILT	0.6 - 0.3		P-PLASTIC VP-VERY PLASTIC
CV-CONVEX SLOPE		SIL-SILT LOAM			
T-TERRACE FP-FLOOD PLAN		CL-CLAY LOAM SCL-SANDY CLAY LOAM			
	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

