

Clayton Homes 12021 Andrew Jackson Hwy Laurinburg, NC 28352 03/22/2021

Attention: Elizabeth Rockwell

RE: Daily Field Report for 03/19/2021

18446 NC 27 West (CMT) Cameron, NC Building & Earth Project No : RD210063

Ladies and Gentlemen:

On this date, representative(s) of Building & Earth were present to perform construction material testing services at this project site. Our testing and observations for this date include the following:

FO-4: Field Observations made on this date.

Foundation Observation

For Information Only

Closing

The testing and observations identified above have been reviewed by our project manager. If you have questions regarding this information, please do not hesitate to contact us.

Respectfully Submitted, Building & Earth Sciences, LLP

Enclosures: FO-4







Field Observations Report

Project Name: 18446 NC 27 West (CMT) Cameron, NC Project Number: RD210063

Client Name: Clayton Homes Placement#: FO-4

Contractor: Clayton Homes Technician: Frank Hamlin

Monitoring: Shallow Footing Testing

1: Foundation Observation

On this date, our representatives returned to the site to confirm repairs at the back right corner column footing. Based upon our observations, the recommended repairs have been accomplished, and the footings now have a bearing capacity of 1,500 psf. See attached photos.



Field Observations Report

Project Name: 18446 NC 27 West (CMT) Cameron, NC Project Number: RD210063

Client Name: Clayton Homes Placement#: FO-4

Contractor: Clayton Homes Technician: Frank Hamlin

Monitoring: Shallow Footing Testing

Photographs

Picture ID	Back Right Corner



27575





Field Observations Report

Project Name: 18446 NC 27 West (CMT) Cameron, NC Project Number: RD210063

Client Name: Clayton Homes Placement#: FO-4

Contractor: Clayton Homes Technician: Frank Hamlin

Monitoring: Shallow Footing Testing

Photographs

Picture ID	Stone beneath Back Right Column Pier
27576	

