

Permit Inspections Harnett County

Permit Number: BRES2010-0060 Description: remove 2 walls/add post(interior work)

Applied: 10/26/2020 Approved: 3/31/2021 Site Address: 24 WEST LNDG

Issued: 10/30/2020 Finaled: City, State Zip Code: SANFORD, NC 27332

Status: APPROVED Applicant: Paul Pepe Jr
Parent Permit: Owner: PEPE PAUL A JR

Parent Project: Contractor: Advanced Structural Repair LLC

Details:

LIST OF INSPECTIONS						
SEQ ID	SCHEDULED DATE	COMPLETED DATE	ТҮРЕ	INSPECTOR	RESULT	REMARKS
			FINAL**	Slade Burton Lawson III		
Notes:						
			FOUNDATION	Slade Burton Lawson III		
Notes:						
			OPEN FLOOR	Slade Burton Lawson III		
Notes:						
			SLAB	Slade Burton Lawson III		
Notes:						
			UNDER SLAB TRADES	Slade Burton Lawson III		
Notes:						
	3/12/2021	3/12/2021	ROUGH IN	Steven Gazlay	DISAPPROVED	
Notes: Rough in for kitchen only cus request late afternoon Inspector SBL changed the inspection assignment from SBL to SPG						
Ok to insulate kitchen and laundry. Framing ok in kitchen, dining and family room. Door and window framing not completed on exterior wall. Doors and windows missing. Seal all plumbing pipes. Add air barriers. Draft stop concealed location.						
	3/29/2021	3/29/2021	ROUGH IN	Steven Gazlay	APPROVED	
Notes:						
Inspector SBL changed the inspection assignment from SBL to SPG						





Permit Inspections Harnett County

3/31/2021 3/31/2021 INSULATION Steven Gazlay APPROVED

Notes:

Inspector SBL changed the inspection assignment from SBL to SPG

