


NOTICE TO CONTRACTOR:
 All construction must comply with current NC Building Codes and is subject to field inspection and verification.

APPROVED
 Limited building only review
 Permit holder responsible for full compliance with the code

02/18/2021





Window must meet egress

Smoke/CO detector tied in w/ existing downstairs

Add Non Load Bearing Walls

Unfinished Storage

Add Non Loan Bearing Wall

To First Floor

Kid's Play Area

Bedroom

Bathroom

Closet