



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

11/1/2021

**SUBJECT: BRES2010-0068**  
**BUILDING RESIDENTIAL**

To: Tauheed Wood

Here are the results of all Inspections located at **425 PAPOOSE TRL:**

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 12/18/2020  
Completed Date/Time: 12/18/2020  
Inspector: Slade Burton Lawson III  
Result: DISAPPROVED  
Remarks: lock box is 1963  
Notes: 12/17/2020 12:59 PM Tauheed Wood

Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com

Poly not complete, insulate water line, unable to gain entry, have set up manual on site

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 12/22/2020  
Completed Date/Time: 12/22/2020  
Inspector: Slade Burton Lawson III  
Result: FAIL W/ PENALTY  
Remarks:  
Notes: Unable to gain entry, insulate water line





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 1/4/2021  
Completed Date/Time: 1/4/2021  
Inspector: Scott Guy  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 12/31/2020 1:15 PM Tauheed Wood  
lock box combo 1963  
Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com

1- Cover and support electrical crossover under home. 2-drain test is down. 3-verify all water supply crossovers are connected.OK to cover marriage walls.

Inspection Type: WATER CONNECTION  
Scheduled Date/Time: 1/4/2021  
Completed Date/Time: 1/4/2021  
Inspector: Scott Guy  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 12/17/2020 1:04 PM Tauheed Wood  
  
Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com

12/31/2020 1:16 PM Tauheed Wood  
  
Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FOOTING  
Scheduled Date/Time: 1/4/2021  
Completed Date/Time: 1/4/2021  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes: 12/17/2020 12:59 PM Tauheed Wood

Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 1/22/2021  
Completed Date/Time: 1/22/2021  
Inspector: Slade Burton Lawson III  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 1/20/2021 8:31 AM Tauheed Wood

1963 is lock box code  
Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com

Inspection Type: ZONING  
Scheduled Date/Time: 1/25/2021  
Completed Date/Time: 1/25/2021  
Inspector: Kyle Holder  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 12/17/2020 12:59 PM Tauheed Wood

Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: 1/22/2021 1:34 PM Tauheed Wood  
Scheduled Date/Time:  
Completed Date/Time: Contact Name: Tauheed Wood  
Inspector: Site Address: 425 PAPOOSE TRL  
Result: Phone: 9109777571  
Remarks: e-Mail: tauheedw@gmail.com  
Notes:

No underpinning / foundation installed

Inspection Type: ADDRESS  
Scheduled Date/Time: 1/25/2021  
Completed Date/Time: 1/29/2021  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 12/17/2020 12:59 PM Tauheed Wood

Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com

1/22/2021 1:33 PM Tauheed Wood  
Lock bock code 1963  
Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com

425 PAPOOSE TRL LILLINGTON 27546.

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time: 1/27/2021  
Completed Date/Time: 1/27/2021  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 12/17/2020 1:05 PM Tauheed Wood

Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: 1/22/2021 1:33 PM Tauheed Wood  
Scheduled Date/Time: Lock box code 1963  
Completed Date/Time: Contact Name: Tauheed Wood  
Inspector: Site Address: 425 PAPOOSE TRL  
Result: Phone: 9109777571  
Remarks: e-Mail: tauheedw@gmail.com  
Notes:

1/22/2021 1:35 PM Tauheed Wood

Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com

Inspector SBL changed the inspection assignment from SBL to SPG  
Cannot glue abs to pvc pipe.

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time: 2/8/2021  
Completed Date/Time: 2/8/2021  
Inspector: Scott Guy  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 2/5/2021 2:41 PM Tauheed Wood

Contact Name: Tauheed Wood  
Site Address: 425 PAPOOSE TRL  
Phone: 9109777571  
e-Mail: tauheedw@gmail.com

Inspector SPG changed the inspection assignment from SPG to TSG

Inspection Type: ZONING INSPECTION  
Scheduled Date/Time: 3/25/2021  
Completed Date/Time: 3/25/2021 1:30 PM  
Inspector: Kyle Holder  
Result: APPROVED  
Remarks:  
Notes: Inspector SBL changed the inspection assignment from SBL to KH





**Harnett County**  
420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: MFH FINAL\*\*

Scheduled Date/Time: 3/29/2021

Completed Date/Time: 3/29/2021

Inspector: Slade Burton Lawson III

Result: DISAPPROVED

Remarks:

Notes: lock box 1993

Address must be visible from road(minimum 4"), no toilets installed

Inspection Type: MFH FINAL\*\*

Scheduled Date/Time: 4/14/2021

Completed Date/Time: 4/14/2021

Inspector: Slade Burton Lawson III

Result: APPROVED

Remarks:

Notes: