Harnett County Department of Public Health

Improvement Permit A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 755 C T Thomas Ln (SR1302) ISSUED TO: Clifford Reynolds SUBDIVISION REPAIR EXPANSION NEW X Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 32' x 62' SFD Proposed Wastewater System Type: Conventional Only Projected Daily Flow: 360 Number of bedrooms: 3 Number of Occupants: 6 Basement Yes X No Pump Required: Yes May be required based on final location and elevations of facilities X Five years Type of Water Supply: Community Public Well Distance from well ______feet Permit valid for: No expiration Permit conditions: Date: 05-06-21 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Clifford Reynolds PROPERTY LOCATION: 755 C T Thomas Ln (SR1302) SUBDIVISION _ Facility Type: 32' x 62' SFD Expansion Basement? Yes × No Basement Fixtures? Yes X No Type of Wastewater System** Conventional Only (Initial) Wastewater Flow: 360 GPD (See note below, if applicable) pump to 25% reduction Number of trenches 3 Installation Requirements/Conditions Trench Spacing: 9 Feet on Center Exact length of each trench 100 Septic Tank Size 1000 gallons Pump Tank Size Trenches shall be installed on contour at a Soil Cover: 6 ____inches gallons Maximum Trench Depth of: 18" - 24" (Maximum soil cover shall not exceed inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. __ inches above pipe Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Moh St RE 11 Date: 05-06-21 Authorized State Agent: Construction Authorization Expiration Date: 05-06-26

Harnett County Department of Public Health Site Sketch

Property Location: 755 C T Thomas Ln (SR1302)		
Issued To: Clifford Reynolds	Subdivision	Lot #
Authorized State Agent:	Mah A- REH	Date: 05-06-21

