

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L	0-10	LS Gr	Fi/ns/np/nxp	10YR 6/2 @ 36"	> 48"			PS .4 Group III
	2-5%	10-48	sci SBk	Fi/sc/sc/pxp					
(2)	L	0-10	LS Gr	Fi/ns/np/nxp	10YR 6/1 < 12"	> 36"			4
	2-5%	10-36	sci SBk	Fi/sc/sc/pxp					
(3)	L	0-10	LS Gr	Fi/ns/np/nxp	10YR 6/2 @ 36"	> 48"			PS .4 Group III
	2-5%	10-48	sci SBk	Fi/sc/sc/pxp					
(4)	L	0-20	LS Gr	Fi/ns/np/nxp	> 48"	> 48"			PS .4 Group III
	2-5%	20-48	sci SBk	Fi/ss/sp/pxp					
(5)	L	0-20	LS Gr	Fi/ns/np/nxp	> 48"	> 48"	-	-	PS .4 Group III
	2-5%	20-48	sci SBk	Fi/ss/sp/pxp					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: M. Borman-REHS Others Present:
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	25% rad	25% rad	
Site LTAR	.4	.4	

COMMENTS: _____


LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM		SP-SLIGHTLY STICKY	
CC-CONCLAVE SLOPE		CL-CLAY LOAM		P-PLASTIC	
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM		VP-VERY PLASTIC	
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M- MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

11-20-2020
 Need to Expose All
 Property Irons

Show profile locations and other site features (dimensions, references or benchmark, and North)



Pins in Road (Warning)