

DAVID MILLER, PE
6300 Creedmoor Rd, STE 170#363
Raleigh, NC 27612
(919) 422-8932 (Office); DAVE@DMA-PA.COM

February 9, 2021

NC Water Heaters
1312 Kirkland Road
Suite 101 ; Raleigh, NC 27603
Dave Noffsinger 919-868-3585 ; Ben Bloomer (919) 353-8355
e-mailed to: info@ncwaterheaters.com ; bloomer.ncwaterheaters@gmail.com

RE: Engineering - Foundation
490 Parker Creek Road
Holly Springs, NC
Project No.: 21DDM-0209F-1

To whom it may concern:

The undersigned arrived on-site 2-9-21 to observe the existing wooden deck framing and left rear screen porch were observed, measured and analyzed. Based on the probing the footings were of adequate size and depth and the underlying bearing materials were firm when probed indicating adequate bearing capacity of 2000 PSF per the 2018 North Carolina State Residential Building Code (NCSBC). The posts at the covered section should be field verified for positive connectivity.

Sincerely,

David Miller, PE

