

February 16, 2021

Geraldine Dorosz  
490 Parker Creek Road  
Holly Springs NC 27540

**RE: Existing Tank Application # BRES2011-0004**

Ms. Dorosz:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

4. **Other – Septic encroachment- Deck built without permits. Drain lines cross under deck (marked onsite). Unable to approve. 5ft setback required off any permitted foundation pillar. Septic relocation shall be applied for and paid for at Central Permitting or soil scientist proposal required. Additionally, outlet end of tank was not uncovered for inspection. Uncover tank and break lid free prior to permitting for inspection required.**

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy - Central Permitting