

February 22, 2021

ph: 910-893-7547

fax: 910-893-9371

NC WaterHeaters.com, LLC
1204 United Drive
Raleigh, NC 27603

RE: Existing Tank Application # BRES2011-0004

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

4. **Other – Septic encroachment- Deck built without permits. Drain lines cross under deck (marked onsite). Unable to approve. 5ft setback required off any permitted foundation pillar. Septic relocation shall be applied for and paid for at Central Permitting or soil scientist proposal required. Additionally, outlet end of tank was not uncovered for inspection. Uncover tank and break lid free prior to permitting for inspection required.**

Your application will be put on hold until the selected items above have been addressed. When completed, call (910) 893-7547 to confirm that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting