



November 20, 2020

Chicora, PLLC

"Success is Sincere Effort and Skillful Execution"

CONSTRUCTION MANAGEMENT • CIVIL DESIGN • CONSULTING

NC Registered Engineering Firm P-1697

SC Registered Engineering Firm No. 6837

Deharo Maricruz
864 Silas Moore Rd
Benson, NC 27504

Reference: Truss Repair
864 Silas Moore Rd
Benson, NC 27504

To whom it may concern,

Chicora, PLLC was requested to evaluate the repairs for the trusses there were constructed on the manufactured home.

The trusses installed were stick built trusses that were built with 2"x 4", and 2"x 6" members. The trusses installed were installed correctly and are structurally sound to support the roof of the manufactured home.

It is in the opinion of the Chicora, PLLC that manufactured home is structurally sound and suitable for the homeowner to proceed with the next phase of construction.

If you have any questions or concerns, please feel free to contact me at (910)740-0725.

Sincerely,

Dennis Lowery, PE

